



Supply Flow Test Data	
Static Pressure	66.000
Residual Pressure	17.000
Flow	695.00

General Notes:  
 First Floor protected by Wet System Throughout  
 Elevation of Mains and Branch Lines 10'-6"  
 Coordinate with Mechanical and Electrical Trades

**First Floor Layout - Fire Sprinkler Layout**  
 1/4" = 1'-0"

	<b>Piping Color Legend</b>	<b>Key Plan</b>
	<ul style="list-style-type: none"> <li>Wet System Branch Line</li> <li>Wet System Main</li> </ul>	

Revisions

		<b>Chinook Fire Protection, Inc.</b> 1221 E. 70th Ave. Anchorage, AK 99518	
		Permit Holder <i>Jeff Wilcheck</i> PERMIT NUMBER: 94-018 NICET IV	Customer: SSAJ Architects Job No. 17C-001 Date 11/02/17 Drawn By Jeffrey Wilcheck Scale 1/8" = 1'-0"

Project: Ouzinkie Office Building Sheet: FP-02  
 Plot Date: 11/09/2017 09:35:46AM